

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 776
AE PHEDated: 03/07/2025It is certified that an inspection team headed by Himanshu Meena (Sub-Eng)(Name of Officers with designation) from PHED (Public Health Eng. Dept)PHED inspected the **CLRR Intellectual International School, Near Railway station, Dahod Road, Mandideep, Dist: Raisen, (M.P)** on 02/07/25 and on the basis of Water Test Report (Attached)bearing no. 776 AE-PHE Oganj dated 03/07/2025of PHED Sub-Div - Obedullaganj (PHED Lab) certified

that the **CLRR Intellectual International School, Near Railway station, Dahod Road, Mandideep, Dist: Raisen, (M.P)** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year

Signature with seal

:-



Name

:-

Shyam Kumar Doley


Designation

:-

Sub-Div. - Obedullaganj
Assistant EngineerName & address of the office/Department: - PHED

To,
CLRR Intellectual International School,
Near Railway station, Dahod Road, Mandideep, Dist: Raisen, (M.P)
(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies



MANAGER
**CLRR INTELLECTUAL
INTERNATIONAL SCHOOL**
Mandideep Distt. Raisen (M.P.)

Excused
PRINCIPAL

**CLRR INTELLECTUAL
INTERNATIONAL SCHOOL**
Mandideep Distt. Raisen (M.P.)

SUB DN LABORATORY..... *Obedullaganj*
Public Health Engineering SUB Division..... *Obedullaganj*

Test Report

Nature of sample:- Drinking Water Sample / Other		Not Sampled by S.D. Lab		Unique Identification No.	
Sander's Name & Address <i>PRINCIPAL CLRR INTELLECTUAL INTERNATIONAL SCHOOL, Mandideep</i>		Sander's Letter No.	Sander's Letter date	<i>01.07.2025</i>	
		S.D. Lab Ref. No.	S.D. Lab Receipt date		
		Date of analysis	<i>02.07.2025</i>	Date of analysis	<i>02.07.2025</i>
		Quantity of sample	OK		

Sample Details

No.	Block	Gram Panchayat	Village	Habitation	Location
1	<i>Obedullaganj</i>	-	-	-	<i>CLRR Intellectual International School, Mandideep, Distt. - Raisen</i>
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					

Details of parameters, their test methods, units and specification as per BIS

No.	Characteristics	Test method BIS edition 3025		Unit	As per BIS-10500:2012 For Drinking Water Reaffirmed in June 2015	
		3	4		Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Source
1	2	3	4	5	6	7
1	Iron Fe	BIS edition	3025	Mg/l	1	1
2	Nitrate as NO3	BIS edition	3025	Mg/l	45	45
3	Fluoride as F	BIS edition	3025	Mg/l	1	1.5
4	Chloride as Cl	BIS edition	3025	Mg/l	250	1000
5	Total Alkalinity as CaCO3	BIS edition	3025	Mg/l	200	600
6	Calcium	BIS edition	3025	Mg/l	75	200
7	Magnesium	BIS edition	3025	Mg/l	30	100
8	Sulphate AS So4	BIS edition	3025	Mg/l	200	400
9	Manganese as Mn	By Kit	Mg/l	0.1	0.3
10	pH	By Meter	PH Scale	6.5 to 8.5	6.5 to 8.5
11	Turbidity	By Meter	NTU	1	5
12	Total hardness as CaCO3	BIS edition	3025	Mg/l	200	600
13	Conductivity	By Meter	micromhos/cm	---	---
14	TDS	By Meter	Mg/l	500	2000
15	Faecal Coliform (TTC)	BIS edition	3025	per 100 ml	NIL	
16	Total Coliform	BIS edition	3025	per 100 ml	NIL for treated water and water in distribution	
17	Arsenic	By Kit	Mg/l	0.01	0.01

This report should not be produced partly or full without approval of signatory authority for legal purposes.

It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable. But still may be tolerated in the alternative source but up to limits indicated under the "permissible limit in the absence source" in column 7, above which the sources will have to be rejected.

The results refer only to tested samples and parameters tested.

Samples will be stored for a period of 15 days from the date of issue of report. (For test from S.No. 1 to 14)

This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

The tests marked with an not accredited by NABL.

PRINCIPAL
Obedullaganj
CLRR INTELLECTUAL INTERNATIONAL SCHOOL
Mandideep Distt. Raisen (M.P.)

MANAGER
Obedullaganj
CLRR INTELLECTUAL INTERNATIONAL SCHOOL
Mandideep Distt. Raisen (M.P.)



Results of Samples


DISTRICT - RAISEN, SUB DIVISION - OBEDULLAGANJ


Senders letter no.		Date: 02.07.2025	S.D. Lab Ref No.										Date - 02.07.2025								Unique Identification No.	
No.	Parameters/Units	Sample Number																				
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
1	Iron in Mg/l	0.24																				
2	Nitrate in Mg/l	0.0																				
3	Fluoride in Mg/l	0.20																				
4	Chloride in Mg/l	55																				
5	Alkalinity in Mg/l	280																				
6	Calcium in Mg/l	-																				
7	Magnesium in Mg/l	-																				
8	Sulphate in Mg/l	96																				
9	Manganese as mg/l	0.0																				
10	pH on pH scale	7.84																				
11	Turbidity in NTU	0.10																				
12	hardness in Mg/l	320																				
13	Conductivity micro / cm	1588																				
14	TDS by meter	1032																				
15	Faecal Coliform (TTC)	0																				
16	Coliform per 100 ml	0																				
17	Arsenic	0.00																				

- This report should not be produced partly or full without approval of signatory authority for legal purposes.
- It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable. But still may be tolerated in the alternative source but up to the limits indicated under the "permissible limit in the absence of alternate source" in column 6, above which the sources will have to be rejected.
- The results refer only to tested samples and parameters tested.
- Samples will be stored for a period of 15 days from the date of issue of report. (For test from s.No. 1 to 14)
- This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
- The tests marked with an not accredited by NABL.

Remarks:- The water sample is found fit for drinking water purpose for the tested parameters.


PRINCIPAL
CLRR INTELLECTUAL
INTERNATIONAL SCHOOL
 Mandideep Distt. Raisen (M.P.)


MANAGER
CLRR INTELLECTUAL
INTERNATIONAL SCHOOL
 Mandideep Distt. Raisen (M.P.)


CHEMIST
PHED. Obedulaganj
CHEMIST
 Sub Divisional Laboratory
 P.W.E. Sub Division, Obedulaganj, Raisen